



# Suburban Water Testing Laboratories, Inc.

4600 KUTZTOWN ROAD, TEMPLE, PA 19560

CERTIFIED LAB ID # 06208

Laboratory Report

 TEMPLE, PA  
(610) 829-3666

 POTTSTOWN, PA  
(610) 326-9180

 WEST CHESTER, PA  
(610) 430-7711


 ALLENTOWN, PA  
(610) 432-0708

 TECHNICAL INFO.  
(610) 929-2920

 FAX  
(610) 829-8321

ID:	98417	DATE:	05/03/99
NAME:	ROBERT & JOANNA SANCHEZ	POINT:	KITCHEN SK
ADDRESS:	963 CHRISLENA LANE	SOURCE:	WELL
	WEST GOSHEN, PA 19380		

ID	Test Name Parameter	Units	Acceptable Levels	Test Result	Pass/Fa
98417 BASIC+	Coliform Bacteria Count	CFU/100 mL	0	0	Pass
	pH	pH	6.5-8.5	8.0	Pass
	Hardness	mg/L as CaCO3	*	160	N/A
	Nitrates as N	mg/L	10	4.0	Pass
	NITRATE AS NO3	mg/L	45	18	Pass
	Fluoride	mg/L	4.0	( 0.1	Pass
	Iron	mg/L	0.3	( 0.05	Pass
	Lead (First Draw)	mg/L	0.015	( 0.001	Pass
	Lead (Second Draw)	mg/L	0.015	( 0.001	Pass
	Copper (First Draw)	mg/L	1.3	0.07	Pass
	Copper (Second Draw)	mg/L	1.3	( 0.02	Pass
	Cadmium (First Draw)	mg/L	0.005	0.0003	Pass
	Cadmium (Second Draw)	mg/L	0.005	0.0001	Pass
	Benzene	PPB	5	( 0.5	Pass
	Carbon Tetrachloride	PPB	5	( 0.5	Pass
	1,2-Dichloroethane	PPB	5	( 0.5	Pass
	o-Dichlorobenzene	PPB	600	( 0.5	Pass
	para-Dichlorobenzene	PPB	75	( 0.5	Pass
	1,1-Dichloroethylene	PPB	7	( 0.5	Pass
	cis-1,2-Dichloroethylene	PPB	70	( 0.5	Pass
	trans-1,2-Dichloroethylene	PPB	100	( 0.5	Pass
	Dichloromethane	PPB	5	( 0.5	Pass
	1,2-Dichloropropane	PPB	5	( 0.5	Pass
	Ethylbenzene	PPB	700	( 0.5	Pass
	Monochlorobenzene	PPB	100	( 0.5	Pass
	Styrene	PPB	100	( 0.5	Pass
	Tetrachloroethylene	PPB	5	( 0.5	Pass
	Toluene	PPB	1000	( 0.5	Pass
	1,2,4-Trichlorobenzene	PPB	70	( 0.5	Pass
	1,1,1-Trichloroethane	PPB	200	( 0.5	Pass
	1,1,2-Trichloroethane	PPB	5	( 0.5	Pass
	Trichloroethylene	PPB	5	( 0.5	Pass
	Vinyl Chloride	PPB	2	( 0.5	Pass
	Xylenes (Total)	PPB	10000	( 0.5	Pass
	Total Trihalomethanes	PPB	100	( 0.5	Pass
	Radon in Water	pCi/L	N/A	1859	N/A
CHESTER	Coliform Bacteria Count	CFU/100 mL	0	0	Pass



# Suburban Water Testing Laboratories, Inc.

4600 KUTZTOWN ROAD, TEMPLE, PA 10660

CERTIFIED LAB ID # 06200

## Laboratory Report

 TEMPLE, PA  
 (610) 929-3666

 POTTSTOWN, PA  
 (610) 326-9100

 WEST CHESTER, PA  
 (610) 430-7711

 ALLENTOWN, PA  
 (610) 432-0708

(610) 929-2920

 FAX  
 (610) 929-8321

ID:	00117	DATE:	05/03/99
NAME:	ROBERT & JOANNA SANCHEZ	POINT:	KITCHEN SK
ADDRESS:	963 CHRISLENA LANE	SOURCE:	WELL
	WEST GOSHEN, PA 19380		

ID	Test Name Parameter	Units	Acceptable Levels	Test Result	Pass/Fail
----	---------------------	-------	-------------------	-------------	-----------

### COMMENTS:

"N/A" = Not Applicable

All parameters are within the maximum contaminant levels (MCL's) listed in Chapter 500 of the Chester County Board of Health water standards for potable water. Hardness is 50 is SOFT water, 51-100 is MODERATELY HARD water, 101-170 is HARD water, 171+ is VERY HARD water. We certify that this sample has been collected by a qualified representative of this laboratory.

Approved by:

Laboratory Director: Richard C. Stuep, II

The acceptable levels indicated are based on the standards listed. These standards may or may not apply to you in a given situation. For questions or recommendations, call (610) 929-2920